



Rang Sarjan Chemicals

Regd. Office & Factory:

C 1-B/408, P. B. No. 32, G.I.D.C. Estate, Ankleshwar - 393002. (Gujarat)

Phone: +91 9998562134/+91 9870001366

E-mail: rangsarjan@gmail.com website: www.rangsarjanchemicals.in

TEST PARAMETERS AND SPECIFICATIONS AND RESULTS

PRODUCT	:	FERRIC CHLORIDE-LIQUID
CAS No.	:	7705 – 08 – 0.
EMPRICAL FORMULA	:	FeCl ₃
TEST	:	IS: 711 – 1970

Sr. No.	Parameters	Specifications	Results
1	Description	Clear Dark Brown Colored Liquid	Complies
2	Ferric Chloride Content	40.0 % Min by Mass	41.50 %
3	Ferrous Chloride Content	0.10 % Max by Mass	0.03 %
4	Insoluble Content in Water	0.05 % Max by Mass	Complies
5	Specific Gravity at 27 °C	1.42 Min	1.48
6	Free acidity as HCL	0.02 % Max by Mass	Complies

CERTIFIED BY (sign/Date): Aniket Mehta 01/01/2025